



Question:

Section 4.2 – Products subsection E - Programmable Logic Controller (PLC) states “2) The PLC shall be IDEC Penta series or equal, Please state the number of I/O required or the actual Idec penta model you want used.

Answer:

As part of the RFP, the prospective bidder shall provide a design which mimics our current non-plc based control panel, including selecting the quantity of I/O points.